



S.S. - 5' FROM C/L (TYP
ON LOW SIDE OF STREET).
SEE NOTES 1 & 2. (3' MIN
CLEAR SEPARATION BETWEEN
SEWER & STORM MAINS)

CURBED STREETS

NTS

NOTES:

1. 6' MIN COVER REQUIRED FOR SANITARY SEWER MAINS
(4' MIN. COVER TYPICALLY REQUIRED FOR SEWER
SERVICE LATERALS W/IN RIGHT-OF-WAY).
2. LATERALS AND P/L CLEANOUTS TO BE INSTALLED
DURING CONSTRUCTION OF SANITARY SEWER & STORM
MAINS (TO AVOID FUTURE STREET CUTS).
3. WATER TO BE INSTALLED 3' IN FRONT OF FACE OF
CURB ON HIGH SIDE OF STREET, UNLESS OTHERWISE
REQUIRED BY THE PUBLIC WORKS DIRECTOR. 36"
MIN. COVER ON ALL WATERLINES. 10' MINIMUM
SEPARATION TYPICAL BETWEEN PARALLEL WATER &
SEWER MAINS.
4. STORM SEWER TO BE INSTALLED ON LOW SIDE OF
STREET:
 - a) 2' FROM FACE OF CURB FOR <4' RIM TO INVERT
 - b) 6' FROM FACE OF CURB FOR >4' RIM TO INVERT
(MH SYSTEM)
5. MAINTAIN MIN. 3' HORIZ. SEPARATION BETWEEN
PUBLIC UTILITIES & PARALLEL PRIVATE UTILITIES.
OTHER VERTICAL AND HORIZONTAL SEPARATION
DISTANCES SHALL BE AS SPECIFIED BY DEQ, ODWP,
OR OTHER PUBLIC/PRIVATE UTILITY COMPANIES.
6. UNITY TRENCH PER FRANCHISE UTILITY COMPANY
REQUIREMENTS, GENERALLY ON THE OPPOSITE SIDE
OF STREET FROM WATERLINE WHERE FEASIBLE.

LAST REVISION DATE:
JAN 2016

COPYRIGHT 1996
WESTECH ENGINEERING, INC.

TYP. UTILITY LOCATIONS (CURBED STREETS)

(NTS)

SILVERTON, OR

DETAIL NO.

101