

NOTES:

- 1. ONLY ALLOWED ON EXISTING PAVED STREETS.
- 2. SAWCUT THROUGH GUTTER PAN SHALL BE MADE AS CLOSE TO CURB FACE AS POSSIBLE.
- 3. COMPLETE CURB AND GUTTER SHALL NOT BE REMOVED UNLESS APPROVED BY THE CITY ENGINEER PRIOR TO START OF CONSTRUCTION.
- 4. WHEN TYPE 'C' CURBS ARE REMOVED, A MINIMUM OF 2 FEET OF PAVEMENT (MEASURED FROM THE FACE OF CURB) SHALL BE REMOVED AND REPLACED UNLESS OTHERWISE APPROVED BY THE CITY
- 5. ANY AC SAWCUTS WILL REQUIRE A BENCH GRIND (PER DETAILS 302A & 302B) IN CONJUNCTION WITH REPAVING.

LAST REVISION DATE:	COPYRIGHT 1995 WESTECH ENGINEERING, INC.
JULY 2015	
CURB KNOCKOUT FOR NEW DRIVEWAYS ON EXISTING CURBED STREETS (NTS)	
	DETAIL NO.
SILVERTON, OR	217