



**NOTES:**

1. PRECAST SECTIONS SHALL CONFORM TO ASTM C-478.
2. DISTANCE FROM TOP OF OVERFLOW TO MH RIM SHALL BE BASED ON OVERFLOW CAPACITY CALC'S BY DESIGN ENGINEER (ASSUME ORIFICE CONTROL).
3. 60" MINIMUM DIA. MANHOLE REQUIRED FOR OUTLET PIPE LARGER THAN 15" OR INLET > 21".
4. ORIFICE CLEANING ACCESS TO BE 6" CORE HOLE THROUGH FLAT-TOP (CENTERED ON OVERFLOW) WITH CI CLEANOUT BOX GROUTED TO SLAB. CORE DRILL HOLE ON SITE AFTER PAVED.

LAST REVISION DATE: 2016	
JULY 2016	
<b>POLLUTION/FLOW CONTROL MANHOLE W/OVERFLOW</b>	
(NTS)	
SILVERTON, OR	DETAIL NO. 320