



**SECTION A-A**

- NOTES:
1. PRECAST SECTIONS SHALL MEET OR EXCEED ASTM C-478.
  2. WATERTIGHT O-RING OR MASTIC KEYLOCK JOINTS REQUIRED.
  3. STEPS TO BE POLYPROPYLENE PLASTIC WITH GRADE 60 REINFORCING ROD. ADD STEPS TO EXTG CONNECTION MH IF EXTG STEPS ARE ABSENT.

LAST REVISION DATE: NOV 2015	COPYRIGHT 1996 WESTECH ENGINEERING, INC.
<b>DEEP MANHOLE FOR 24" AND 27" PIPE</b>	
(NTS)	
SILVERTON, OR	DETAIL NO. <b>403A</b>