



**NOTES:**

1. ALL INSIDE DROPS MUST BE APPROVED ON A CASE BY CASE BASIS BY THE PUBLIC WORKS SUPERINTENDANT. MINIMUM 60" DIAMETER MANHOLE REQUIRED FOR INSIDE DROPS UNLESS OTHERWISE APPROVED IN WRITING BY THE PUBLIC WORKS SUPERINTENDANT.
2. "RELINER" INSIDE DROP BOWL BY DURAN, INC. OR APPROVED EQUIVALENT. FOR INLET PIPES WITH SLOPES GREATER THAN 5%, PROVIDE BOWL WITH OPTIONAL HOOD.
3. ALL PIPE PENETRATIONS SHALL HAVE NEOPRENE RUBBER BOOTS. MANHOLE BASE, BARREL & TOP TO CONFORM WITH DETAILS 401-403A.

4. STEPS TO BE POLYPROPYLENE PLASTIC WITH GRADE 60 REINFORCING ROD. ADD STEPS TO EXTG CONNECTION MH IF EXTG STEPS ARE ABSENT.

LAST REVISION DATE: JULY 2015	
<b>INSIDE DROP CONNECTION FOR SANITARY SEWER OR STORM MANHOLE</b>	
(NTS)	
SILVERTON, OR	DETAIL NO. <b>404</b>