



NOTES:

1. BFV SHALL BE SHORT BODY TYPE B VALVE PER AWWA C-504.
2. VALVE BOXES SHALL BE PLUMB AND CENTERED DIRECTLY OVER THE VALVE NUT.
3. VALVE BOX TOP SHALL BE ADJUSTED TO FINISHED GRADE.
4. PVC SHALL BE ONE CONTINUOUS PIECE, NO BELLS OR COUPLERS.
5. BFV ACTUATOR TO BE LOCATED ON THE CURBLINE SIDE OF WATERLINE AS SHOWN. INSTALL DI SPOOLS OR FLEX ADAPTER IF REQUIRED FOR ACTUATOR CLEARANCE.

LAST REVISION DATE: JULY 2015	JO # STANDARD
BUTTERFLY VALVE AND VALVE BOX DETAILS	
(NTS)	
SILVERTON, OR	DETAIL NO. 502