



-FDC LINE CHECK VALVE & BALL DRIP VALVE TO BE INSTALLED IN AN ACCESSIBLE LOCATION PER NFPA 13, 8.17.2.5&6.
 -CONTRACTOR TO VERIFY THAT BALL DRIP VALVE INSTALLED IS LISTED FOR THE ORIENTATION USED (VERTICAL TYP).

MH, VAULT OR BOX STRUCTURE OVER CHECK VALVE OR BALL-DRIP VALVE, SEE NOTE 1. CHECK VALVE AND/OR BALL DRIP VALVE TO BE EXPOSED & ACCESSIBLE FOR INSPECTION & MAINTENANCE.

PROVIDE BALL DRIP DRAIN VALVE, CONNECTED TO CHECK VALVE (UNLESS CHECK VALVE IS INSIDE BUILDING), OR TO SERVICE SADDLE ON FDC LINE

GLOBE OR WAFER STYLE SILENT CHECK VALVE OR APPROVED EQUAL.

MEGA FLANGE ADAPTER OR EQUAL (2 PL)

FDC LINE PER OFC

FDC LINE TO BLDG

CONCRETE THRUST COLLAR W/ RETAINER GLAND (PLASTIC WRAPPED) CENTERED IN CONCRETE, UNLESS FDC PIPE FULLY RESTRAINED

SLOPE SHELF TO DRAIN
 DRAIN LINE TO STORM SYSTEM OR TO DAYLIGHT

NOTES:

1. INSTALL 48" PRECAST MANHOLE PER DETAIL 402, UNLESS OTHER APPROVED VAULT OR BOX IS SHOWN OR NOTED ON DWGS.
2. ALL PIPE OPENINGS SHALL BE SEALED WITH NON-SHRINK WATERTIGHT GROUT.
3. WHERE REQUIRED, THRUST COLLAR CONCRETE SHALL BE 3300 PSI @ 28 DAYS.
4. IF AN FDC LINE CHECK VALVE IS PROVIDED INSIDE BUILDING, AN EXTERIOR FDC LINE CHECK VALVE IS NOT REQUIRED UNLESS OTHERWISE DIRECTED IN WRITING BY FIRE CODE OFFICIAL. BALL DRIP DRAIN VALVE SHALL BE INSTALLED ON CHECK VALVE OR AT LOW POINT ON FDC LINE (DETAIL 562) TO DRAIN FDC LINE BETWEEN CHECK VALVE & FDC RISER.
5. PER NFPA 13, A10.4.1, 36" MIN COVER REQUIRED FOR "WET" FDC LINES (ANY PORTION OF FDC LINE WHICH REMAINS FILLED WHEN NOT IN USE). COVER MAY BE REDUCED TO 12" MIN ON "DRY" FDC LINE WHICH IS DRAINED COMPLETELY WHEN NOT IN USE.
6. THIS DETAIL DOES NOT SUPERCEDE REQUIREMENTS UNDER THE OREGON FIRE CODE, NFPA STANDARDS OR DIRECTION FROM FIRE CHIEF.

LAST REVISION DATE: JULY 2015	JO # STANDARD
BELOW GRADE CHECK VALVE & BALL DRIP VALVE, IN CLOSE BOTTOM DRAIN STRUCT (NTS)	
SILVERTON, OR	DETAIL NO. 560